



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Bach Elementary School							
Date of Sampling: 10/20/18							
Sampler: Lauren Koloski							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Bach-02	Staff Lounge, Faucet	F	6:41 AM	5	2	Y	First Draw. Aerator Dirty.
Bach-13	Room 202, Faucet	C	6:54 AM	5	2	Y	First Draw
Bach-14	Room A-24, Faucet	C	7:42 AM	5	2	N	First Draw
Bach-15	Room A-26, Faucet	C	7:40 AM	5	5	N	First Draw
Bach-16	Room A-25, Faucet	C	7:41 AM	5	1	N	First Draw
Bach-17	Room 19, Faucet	C	7:18 AM	5	3	N	First Draw
Bach-18	Room A-29, Faucet	C	7:30 AM	5	2	N	First Draw
Bach-19	Room 18, Faucet	C	7:20 AM	5	2	N	First Draw
Bach-20	Room 16, Faucet	C	7:22 AM	5	ND ³	Y	First Draw
Bach-21	Kitchen, 3-Compartment Sink, Right Faucet	KF	7:56 AM	5	ND	Y	First Draw
Bach-22	Kitchen, 3-Compartment Sink, Left Faucet	KF	7:50 AM	5	ND	Y	First Draw
Bach-23	Room 21, Bubbler	C	7:14 AM	5	1	N	First Draw
Bach-24	Room 23, Bubbler	C	7:06 AM	5	1	N	First Draw
Bach-25	Room 23, Faucet	C	7:06 AM	5	2	N	First Draw
Bach-26	Room 22, Bubbler	C	7:09 AM	5	2	N	First Draw
Bach-27	Room 22, Faucet	C	7:09 AM	5	1	N	First Draw
Bach-28	Room A-27, Bubbler	C	7:38 AM	5	ND	N	First Draw
Bach-29	Room A-27, Faucet	C	7:38 AM	5	1	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminante>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Bach Elementary School							
Date of Sampling: 10/20/18							
Sampler: Lauren Koloski							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Bach-30	Room 20, Faucet	C	7:12 AM	5	5	N	First Draw
Bach-31	Room 31, Clinic	F	6:47 AM	5	2	Y	First Draw
Bach-32	Auditorium, Faucet	F	7:01 AM	5	ND	Y	First Draw
Bach-33	Auditorium, Bottle Fill	BF	6:58 AM	5	ND	N	First Draw
Bach-34	Hallway, Outside Media Center, Bottle Fill	BF	6:51 AM	5	ND	N	First Draw
Bach-35	Room A-28, Bubbler	C	7:37 AM	5	ND	N	First Draw
Bach-36	Room A-28, Faucet	C	7:37 AM	5	2	N	First Draw
Bach-37	Room C-104, Faucet	F	6:30 AM	5	ND	N	First Draw
Bach-38	Room 21, Faucet	C	7:14 AM	5	2	N	First Draw
Bach-39	Hallway, Outside Media Center, Bottle Fill, Water Cooler	BF	6:51 AM	5	ND	N	First Draw.
Bach-40	Auditorium, Bottle Fill, Water Cooler	BF	6:58 AM	5	ND	N	First Draw.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminante>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Bach Elementary School							
Date of Sampling: 10/27/18							
Sampler: Jenna Sendra							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Bach-01	Room 202, Bubblers	C	8:36 AM	5	ND	N	First Draw
Bach-03	Room A-24, Bubblers	C	8:33 AM	5	ND	N	First Draw
Bach-04	Room A-25, Bubblers	C	8:30 AM	5	1	N	First Draw. Brown Discoloration on Mouthpiece.
Bach-05	Room A-26, Bubblers	C	8:26 AM	5	1	N	First Draw
Bach-06	Room A-29, Bubblers	C	8:22 AM	5	ND	N	First Draw
Bach-07	Room 19, Bubblers	C	8:45 AM	5	4	N	First Draw. Lower than Typical Flow
Bach-08	Room 20, Bubblers	C	8:46 AM	5	4	N	First Draw
Bach-09	Room 18, Bubblers	C	8:40 AM	5	2	N	First Draw
Bach-10	Room 16, Bubblers	C	8:37 AM	5	1	N	First Draw. Brown Discoloration on Mouthpiece.
Bach-11	Hallway Outside Room 104, Bubblers	B	8:52 AM	5	ND	N	First Draw. Discoloration on Mouthpiece.
Bach-12	Hallway Outside Room 306, Bubblers	B	8:55 AM	5	ND	N	First Draw. Discoloration on Mouthpiece.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb