



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Eberwhite Elementary School							
Date of Sampling: October 27, 2018							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Eberwhite-01	Room 113, Bubbler	B	12:49 PM	5	4	N	First Draw
Eberwhite-02	Hallway, Outside Library, Water Cooler	WC	12:47 PM	5	ND ³	N	First Draw. Scale on Sides of Mouthpiece. Water cooler was reviewed against the EPA Fact Sheet to determine that it is not a lead lined.
Eberwhite-03	Room 111, Bubbler	B	12:45 PM	5	2	N	First Draw. Low/Inconsistent Flow.
Eberwhite-04	Room 127, Bubbler	B	1:10 AM	5	2	N	First Draw
Eberwhite-05	Room 115, Faucet	F	12:52 PM	5	6	N	First Draw
Eberwhite-06	Room 125. Bubbler	C	1:02 AM	5	1	N	First Draw
Eberwhite-07	Library, Faucet	F	12:43 PM	5	4	N	First Draw
Eberwhite-08	Hallway, Outside Main Office, Water Cooler	WC	12:30 PM	5	ND	N	First Draw. Inconsistent Flow. Water cooler was reviewed against the EPA Fact Sheet to determine that it is not a lead lined.
Eberwhite-09	Hallway, Outside Room 122, Left Bubbler	B	1:04 AM	5	4	N	First Draw. Scale and Rust on Mouthpiece.
Eberwhite-10	Hallway, Outside Room 122, Right Bubbler	B	1:05 AM	5	3	N	First Draw. Scale and Rust on Mouthpiece.
Eberwhite-11	Hallway, Outside Main Office, Bottle Fill	BT	12:32 PM	5	ND	N	First Draw.
Eberwhite-12	Hallway, Outside Main Office, Bottle Fill, Water Cooler	BT	12:34 PM	5	1	N	First Draw. Water cooler was reviewed against the EPA Fact Sheet to determine that it is not a lead lined.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Eberwhite Elementary School							
Date of Sampling: October 27, 2018							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Eberwhite-13	Room 10, Faucet	F	1:51 AM	5	1	N	First Draw
Eberwhite-14	Room 135, Faucet	F	1:45 AM	5	1	N	First Draw
Eberwhite-15	Kitchen, 2-Compartment Sink, Left Faucet	KF	12:37 PM	5	1	N	First Draw. Faucet Drips.
Eberwhite-16	Faucet	KF	12:38 PM	5	2	N	First Draw
Eberwhite-17	Kitchen, 1-Compartment Sink	KF	12:39 PM	5	2	N	First Draw. Faucet Drips.
Eberwhite-18	Room 116, Faucet	F	12:27 PM	5	2	Y	First Draw
Eberwhite-19	Room 120, Bubbler	B	12:55 PM	5	1	N	First Draw
Eberwhite-20	Room 122, Bubbler	B	1:08 AM	5	2	N	First Draw
Eberwhite-21	Room 129, Bubbler	B	Not Sampled.			N	Low Flow.
Eberwhite-22	Room 131, Bubbler	B	1:27 AM	5	2	N	First Draw
Eberwhite-23	Hallway, Outside Room 126, Left Bubbler	B	1:22 AM	5	3	N	First Draw
Eberwhite-24	Hallway, Outside Room 126, Right Bubbler	B	1:23 AM	5	7	N	First Draw. Scale on Mouthpiece.
Eberwhite-25	Room 126, Bubbler	B	1:25 AM	5	14	N	First Draw
Eberwhite-26	Room 124, Bubbler	B	1:15 AM	5	2	N	First Draw. Slow Flow.
Eberwhite-27	Room 133, Bubbler	C	1:30 AM	5	2	N	First Draw. Scale on Mouthpiece.
Eberwhite-28	Room 133, Faucet	C	1:31 AM	5	6	N	First Draw
Eberwhite-29	Room 132, Bubbler	C	1:35 AM	5	3	N	First Draw
Eberwhite-30	Room 132, Faucet	C	1:36 AM	5	2	N	First Draw. Faucet Drips.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminante>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Eberwhite Elementary School							
Date of Sampling: October 27, 2018							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Eberwhite-31	Room 134, Bubbler	C	1:40 AM	5	6	N	First Draw
Eberwhite-32	Room 134, Faucet	C	1:41 AM	5	12	N	First Draw
Eberwhite-33	Room 114, Bubbler	B	12:05 PM	5	2	N	First Draw. Sporadic Flow.
Eberwhite-34	Room 102, Bubbler	B	12:00 PM	5	9	N	First Draw
Eberwhite-35	Room 112, Bubbler	B	12:07 PM	5	2	N	First Draw
Eberwhite-36	Room 110, Bubbler	B	12:18 PM	5	3	N	First Draw
Eberwhite-37	Hallway, Outside Room 106, Water Cooler	WC	12:10 PM	5	ND	N	First Draw
Eberwhite-38	Hallway, Outside Room 106, Bottle Fill	BT	12:12 PM	5	ND	Y	First Draw. water cooler was reviewed against the EPA Fact Sheet to determine that it is not a lead lined.
Eberwhite-39	Hallway, Outside Room 106, Bottle Fill, Water Cooler	BT	12:14 PM	5	1	N	First Draw
Eberwhite-40	Room 106, Bubbler	B	12:09 PM	5	2	N	First Draw. Low Flow.
Eberwhite-41	Room 108, Bubbler	B	12:20 PM	5	3	N	First Draw
Eberwhite-42	Gym, Bubbler	B	Not Sampled.			Y	Out of Service.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb