



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Haisley Elementary School							
Date of Sampling: 10/20/18							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Haisley-07	Main Office, Nurse's Sink Faucet	F	9:30 AM	5	2	Y	First Draw
Haisley-08	Room 106, Faucet	C	10:09 AM	5	ND ³	N	First Draw
Haisley -12	Main Office Kitchen, Faucet	KF	9:35 AM	5	3	Y	First Draw
Haisley -13	Room 109, Right Combo Bubblers	C	10:01 AM	5	1	N	First Draw
Haisley -14	Hallway Across Room 200, Bottle Fill, Water Cooler Outlet	BT	10:32 AM	5	ND	N	First Draw
Haisley -15	Room 109, Right Combo Faucet	C	9:59 AM	5	3	Y	First Draw
Haisley -16	Room 109, Left Combo Bubblers	C	9:57 AM	5	1	N	First Draw
Haisley -17	Room 109, Left Combo Faucet	C	9:55 AM	5	4	Y	First Draw
Haisley -18	Room 105, Bubblers	C	10:10 AM	5	ND	N	First Draw
Haisley -19	Room 105, Faucet	C	10:11 AM	5	ND	Y	First Draw
Haisley -20	Room 103, Bubblers	C	10:16 AM	5	ND	N	First Draw
Haisley -21	Room 103, Faucet	C	10:17 AM	5	1	Y	First Draw
Haisley -22	Room 101, Bubblers	C	10:18 AM	5	2	N	First Draw
Haisley -23	Room 101, Faucet	C	10:19 AM	5	2	Y	First Draw
Haisley -24	Room 100, Bubblers	C	10:22 AM	5	1	N	First Draw
Haisley -25	Room 100, Faucet	C	10:23 AM	5	3	Y	First Draw
Haisley -26	Room 104, Bubblers	C	10:14 AM	5	1	N	First Draw
Haisley -27	Room 104, Faucet	C	10:12 AM	5	ND	Y	First Draw
Haisley -28	Room 108, Bubblers	C	10:07 AM	5	ND	N	First Draw
Haisley -29	Room 108, Faucet	C	10:05 AM	5	ND	Y	First Draw

1) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Haisley Elementary School							
Date of Sampling: 10/20/18							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Haisley -34	Multi-Purpose Room, Water Cooler	WC	10:45 AM	5	ND	N	First Draw. Water cooler was reviewed against the EPA Fact Sheet to determine that it is not a lead lined.
Haisley -35	Multi-Purpose Room, Bottle Fill Outlet	BT	10:46 AM	5	ND	Y	First Draw
Haisley -36	Multi-Purpose Room, Bottle Fill, Water Cooler	BT	10:48 AM	5	ND	N	First Draw. Water cooler was reviewed against the EPA Fact Sheet to determine that it is not a lead lined.
Haisley -37	Room 113, Faucet	F	10:30 AM	5	1	Y	First Draw
Haisley -38	Room 304, Faucet	C	11:10 AM	5	1	Y	First Draw
Haisley -39	Room 202, Faucet	C	10:42 AM	5	ND	Y	First Draw
Haisley -40	Room 204, Bubblers	C	10:50 AM	5	ND	N	First Draw. Low flow.
Haisley -41	Room 204, Faucet	C	10:51 AM	5	2	Y	First Draw
Haisley -42	Room 206, Bubblers	C	10:55 AM	5	ND	N	First Draw
Haisley -43	Room 206, Faucet	C	10:56 AM	5	6	Y	First Draw
Haisley -44	Room 400, Bubblers	C	11:23 AM	5	5	N	First Draw
Haisley -45	Room 400, Faucet	C	11:24 AM	5	7	Y	First Draw
Haisley -46	Room 402, Bubblers	C	11:26 AM	5	2	N	First Draw
Haisley -47	Room 402, Faucet	C	11:27 AM	5	2	Y	First Draw
Haisley -48	Room 404, Bubblers	C	11:29 AM	5	4	N	First Draw
Haisley -49	Room 404, Faucet	C	11:30 AM	5	12	Y	First Draw
Haisley -50	Room 406, Bubblers	C	11:33 AM	5	2	N	First Draw
Haisley -51	Room 406, Faucet	C	11:34 AM	5	5	Y	First Draw

1) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861

Haisley Elementary School							
Date of Sampling: 10/20/18							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Haisley -52	Room 300, Bubblers	C	11:00 AM	5	ND	N	First Draw
Haisley -57	Room 304, Bubblers	C	11:09 AM	5	ND	N	First Draw
Haisley -58	Room 306, Bubblers	C	11:15 AM	5	1	N	First Draw
Haisley -59	Room 306, Faucet	C	11:16 AM	5	2	Y	First Draw
Haisley -60	Room 307, Bubblers	C	11:17 AM	5	ND	N	First Draw
Haisley -61	Room 307, Faucet	C	11:18 AM	5	1	Y	First Draw
Haisley -62	Room 305, Bubblers	C	11:12 AM	5	ND	N	First Draw
Haisley -63	Room 305, Faucet	C	11:13 AM	5	ND	Y	First Draw
Haisley -64	Music Room, Faucet	F	10:36 AM	5	17	Y	First Draw

1) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Haisley Elementary School							
Date of Sampling: 10/27/18							
Sampler: Jenna Sendra							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Haisley-01	Hallway Across Room 114, Water Cooler	WC	9:27 AM	5	ND	N	First Draw. Water cooler was reviewed against the EPA Fact Sheet to determine that it is not a lead lined.
Haisley-02	Hallway Across Room 200, Bottle Fill Outlet	BF	9:40 AM	5	ND	N	First Draw
Haisley-03	Room 200, Bubblers	C	9:43 AM	5	ND	N	First Draw
Haisley-04	Room 200, Faucet	C	9:44 AM	5	ND	Y	First Draw
Haisley-05	Room 112, Bubblers	C	9:31 AM	5	ND	N	First Draw
Haisley-06	Room 112, Faucet	C	9:31 AM	5	ND	Y	First Draw
Haisley-09	Room 106, Bubblers	C	9:34 AM	5	ND	N	First Draw. Small amounts of rust around bubbler mouthpiece.
Haisley-10	Room 102, Faucet	C	9:36 AM	5	ND	Y	First Draw
Haisley-11	Room 102, Bubblers	C	9:37 AM	5	ND	N	First Draw

1) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested