



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

| Burns Park Elementary School | | | | | | | |
|------------------------------------|---|-------------------|----------------|------------------------------|---------------------|---------------------|-----------------------|
| Date of Sampling: January 29, 2022 | | | | | | | |
| Sampler: Sabrina Fouche | | | | | | | |
| Sample # | Location | Type ¹ | Time Collected | Internal Action Level (ug/L) | Lead Results (ug/L) | Aerator Present Y/N | Notes |
| Burns-01 | Room 110, Combination Sink, Glass Filler | C | 10:34 AM | 5 | ND ³ | Yes | First Draw, Filtered. |
| Burns-04 | Room 213, Combination Sink, Glass Filler | C | 11:10 AM | 5 | ND | Yes | First Draw, Filtered. |
| Burns-09 | Room 103, Combination Sink, Glass Filler | C | 10:43 AM | 5 | ND | Yes | First Draw, Filtered. |
| Burns-15 | Room A-5, Combination Sink, Glass Filler | C | 10:57 AM | 5 | ND | Yes | First Draw, Filtered. |
| Burns-21 | Room A-4, Combination Sink, Glass Filler | C | 10:49 AM | 5 | ND | Yes | First Draw, Filtered. |
| Burns-27 | Hallway, Outside Room 110, Porcelain, Glass Filler | GF | 10:30 AM | 5 | ND | Yes | First Draw, Filtered. |
| Burns-42 | Room 307, Combination Sink, Glass Filler | C | 11:24 AM | 5 | 15 | Yes | First Draw, Filtered. |
| Burns-48 | Hallway, Outside Media Center, Hydration Station, Bottle Fill | HS | 11:18 AM | 5 | ND | Yes | First Draw, Filtered. |

- 1) Type: B = Bubblers, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb