



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Huron High School							
Date of Sampling: January 22, 2022							
Sampler: Sabrina Fouche							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Huron-01	Hallway, Southeast Wing, Floor 1, Across from Room 6156, Refrigerated, Glass Filler	GF	3:25 PM	5	ND ³	N	First Draw, Filtered.
Huron-05	Fitness Center, Northwest Hydration Station, Bottle Fill	HS	3:12 PM	5	ND	Y	First Draw, Filtered.
Huron-09	Hallway, Northwest Wing, Outside of Cafeteria, Left Hydration Station, Bottle Fill	HS	3:03 PM	5	ND	Y	First Draw, Filtered.
Huron-15	Floor 1, Northwest Wing, Fitness Center, Refrigerated, Glass Filler	GF	3:10 PM	5	ND	N	First Draw, Filtered.
Huron-18	Hallway, Northwest Wing, Floor 1, Near Fitness Center, Right Refrigerated, Glass Filler	GF	3:16 PM	5	ND	N	First Draw, Filtered.
Huron-22	Hallway, Northwest Wing, Outside of Cafeteria, Right Hydration Station, Bottle Fill	HS	3:02 PM	5	ND	Y	First Draw, Filtered.
Huron-27	Room 7104, Refrigerated, Glass Filler	GF	3:42 PM	5	ND	N	First Draw, Filtered.

- 1) Type: B = Bubblers, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Huron High School							
Date of Sampling: January 22, 2022							
Sampler: Sabrina Fouche							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Huron-29	Kitchen, Plumbed Coffee Machine	PC	2:59 PM	5	15	N	First Draw, No Filter.
Huron-32	Kitchen, Single Sink, Faucet	KF	2:52 PM	5	ND	Y	First Draw, Filtered.
Huron-41	Hallway, Northwest Wing, Floor 2, Across from Room 2201, Refrigerated, Glass Filler	GF	3:59 PM	5	ND	N	First Draw, Filtered.
Huron-48	Hallway, Northwest Wing, Floor 2, Outside Upper Gym, Refrigerated, Glass Filler	GF	4:03 PM	5	ND	N	First Draw, Filtered.
Huron-56	Life Skills Room 6219, East Wall, Right, 2-Compartment Sink, Combination Sink, Glass Filler	C	3:51 PM	5	ND	N	First Draw, Filtered.
Huron-62	Life Skills Room 6219, West Wall, Right, 2-Compartment Sink, Combination Sink, Glass Filler	C	3:53 PM	5	ND	N	First Draw, Filtered.
Huron-72	Hallway, Floor 1, Southeast Wing, Outside Room 7109, Hydration Station, Bottle Fill	HS	3:35 PM	5	ND	Y	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Huron High School							
Date of Sampling: January 22, 2022							
Sampler: Sabrina Fouche							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Huron-77	Hallway, Northwest Wing, Floor 2, Across from Room 3201, Hydration Station, Bottle Fill	HS	4:11 PM	5	ND	Y	First Draw, Filtered.
Huron-81	Hallway, Floor 3, Outside Room 4321, Hydration Station, Bottle Fill	HS	4:07 PM	5	ND	Y	First Draw, Filtered.
Huron-84	Hallway, Southeast Wing, Floor 1, Outside of Media Center, Right Hydration Station, Bottle Fill	HS	3:21 PM	5	ND	Y	First Draw, Filtered.
Huron-85	Kitchen, Northwest Corner, Ice Machine	I	2:54 PM	5	ND	N	First Draw, Filtered.
Huron-102	Hallway, Southeast Wing, Floor 2, Across Room 5200, Hydration Station, Bottle Fill	HS	3:46 PM	5	ND	Y	First Draw, Filtered.
Huron-103	Hallway, Southeast Wing, Floor 1, Across Room 7152, Hydration Station, Bottle Fill	HS	3:30 PM	5	ND	Y	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb