



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030

Westerman Preschool							
Date of Sampling: February 16, 2022							
Sampler: Zachary Fortin							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
PFC-88A	Classroom D107 Bathroom, Left Faucet	PB	6:17 PM	5	ND ³	Y	First Draw Following Filter Replacement.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb