



Ann Arbor Public Schools
Legionella Sampling Analysis
Project Number: AE200779

Ann Arbor Open at Mack										
Date of Sampling: 11-4-2020										
Sampler: Jackie Keeler										
Sample #	Location	Time Collected	Bottle Type	Chlorine (ppm)	Temp °C	pH	Legionella Pneumophila Lab Result	Other Legionella Species ³ Lab Results	Total Legionella raw ct.	Total Legionella (cfu (colony forming units)/ml)
A2SOM-13	Room 306, Kitchen Faucet	12:50 PM	Bioswab	0.00	33.4	8.97	ND	ND	ND	<20
A2SOM-13	Room 306, Kitchen Faucet	12:55 PM	1 Liter	0.00	33.4	8.97	ND	ND	ND	<0.1
A2SOM-21	Room 107, Combination Sink, Faucet	1:10 PM	Bioswab	0.02	33.8	8.98	ND	ND	ND	<20
A2SOM-21	Room 107, Combination Sink, Faucet	1:15 PM	1 Liter	0.02	33.8	8.98	ND	ND	ND	<0.1

1) <0.1 is the detection limit for Legionella in bulk water samples
 2) <20 is the detection limit for Legionella in bioswab samples
 3) See attached analytical results for full list of other Legionella species

Ann Arbor Open at Mack Sampling Results Table

Ann Arbor Open at Mack				
Location	Parameter	Result	MCL/AL	Method Reference
A2SOM-13: Room 306 Kitchen Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
	Total Residual Chlorine	0.01 PPM	N/A	N/A
A2SOM-21: Room 107, Combination Sink, Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
A2SOM-22: Room 201, Single Sink, Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
A2SOM-47: Room 247, Combination Sink, Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
A2SOM-61: Gym Entrance Door, Outside Men's Locker Room, Hydration Station, Bottle Fill	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035