



**Ann Arbor Public Schools**  
**Legionella Sampling Analysis**  
**Project Number: AE200779**

Bryant Elementary School										
Date of Sampling: 11-11-20										
Sampler: Brendan Koziol										
Sample #	Location	Time Collected	Bottle Type	Chlorine (ppm)	Temp °C	pH	Legionella Pneumophila Lab Result	Other Legionella Species <sup>3</sup> Lab Results	Total Legionella raw ct.	Total Legionella (cfu (colony forming units)/ml)
Bryant-NP-01	Kitchen, 3 Compartment Sink, Left Nonpotable Faucet	9:00 AM	Bioswab	0.00	20.1	9.07	ND	ND	ND	<20
Bryant-NP-01	Kitchen, 3 Compartment Sink, Left Nonpotable Faucet	9:04 AM	1 Liter	0.00	20.1	9.07	ND	ND	ND	<0.1
Bryant-NP-02	Room C-213, Bathroom, Bathroom Faucet	8:45 AM	1 Liter	0.00	18.9	9.15	ND	ND	ND	<0.1
Bryant-02	Teachers Lounge Sink, Faucet	9:15 AM	1 Liter	0.00	20.9	9.24	ND	ND	ND	<0.1

- 1) <0.1 is the detection limit for Legionella in bulk water samples
- 2) <20 is the detection limit for Legionella in bioswab samples
- 3) See attached analytical results for full list of other Legionella species



Ann Arbor Public Schools  
Legionella Sampling Analysis  
Project Number: AE200779

Bryant Elementary School										
Date of Sampling: 11-05-20										
Sampler: Brendan Koziol										
Sample #	Location	Time Collected	Bottle Type	Chlorine (ppm)	Temp °C	pH	Legionella Pneumophila Lab Result	Other Legionella Species <sup>3</sup> Lab Results	Total Legionella raw ct.	Total Legionella (cfu (colony forming units)/ml)
Bryant-HWH	Hot Water Heater in Mechanical/Boiler Room	10:32 AM	1 Liter	0.07	36.5	7.52	ND	ND	ND	<0.1

1) <0.1 is the detection limit for Legionella in bulk water samples

2) <20 is the detection limit for Legionella in bioswab samples

3) See attached analytical results for full list of other Legionella species