



**Ann Arbor Public Schools  
Legionella Sampling Analysis  
Project Number: AE200779**

<b>Lakewood Elementary School</b>										
<b>Date of Sampling: 11-04-20</b>										
<b>Sampler: Jackie Keeler</b>										
Sample #	Location	Time Collected	Bottle Type	Chlorine (ppm)	Temp °C	pH	Legionella Pneumophila Lab Result	Other Legionella Species <sup>3</sup> Lab Results	Total Legionella raw ct.	Total Legionella (cfu (colony forming units)/ml)
Lakewood-24	A Wing, Common Room, Outside Room A6, Single Sink, Faucet	11:30 AM	Bioswab	0.00	30.1	8.37	ND	ND	ND	<20
Lakewood-24	A Wing, Common Room, Outside Room A6, Single Sink, Faucet	11:35 AM	1 Liter	0.00	30.1	8.37	ND	ND	ND	<0.1
Lakewood-34	Room 107, Combination Sink, Faucet	11:45 AM	Bioswab	0.04	30.8	8.84	ND	ND	ND	<20
Lakewood-34	Room 107, Combination Sink, Faucet	11:50 AM	1 Liter	0.04	30.8	8.84	ND	ND	ND	<0.1
Lakewood-47	Room D3, Combination Sink, Faucet	12:00 PM	Bioswab	0.04	32.7	9.06	ND	ND	ND	<20
Lakewood-47	Room D3, Combination Sink, Faucet	12:05 PM	1 Liter	0.04	32.7	9.06	ND	ND	ND	<0.1

1) <0.1 is the detection limit for Legionella in bulk water samples  
 2) <20 is the detection limit for Legionella in bioswab samples  
 3) See attached analytical results for full list of other Legionella species

Lakewood Elementary School Sampling Results Table

Lakewood Elementary School				
Location	Parameter	Result	MCL/AL	Method Reference
Lakewood-03: Room 103, Single Sink, Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
Lakewood-11: Kitchen, Three-Compartment Sink, Single Add On Faucet, Far Right	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
Lakewood-24: A Wing, Common Room, Outside Room A-6, Single Sink, Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
Lakewood-34: Room 107, Combination Sink, Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
	Total Residual Chlorine	0.0 PPM	N/A	N/A
Lakewood-47: Room D-3, Combination Sink, Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035