



**Ann Arbor Public Schools
Legionella Sampling Analysis
Project Number: AE200779**

Pittsfield Elementary School										
Date of Sampling: 10-28-20										
Sampler: Jackie Keeler										
Sample #	Location	Time Collected	Bottle Type	Chlorine (ppm)	Temp °C	pH	Legionella Pneumophila Lab Result	Other Legionella Species ³ Lab Results	Total Legionella raw ct.	Total Legionella (cfu (colony forming units)/ml)
Pittsfield-02	Staff Lounge, Kitchen Faucet	2:15 PM	Bioswab	0.01	38.7	8.32	ND	ND	ND	<20
Pittsfield-02	Staff Lounge, Kitchen Faucet	2:20 PM	1 Liter	0.01	38.7	8.32	ND	ND	ND	<0.1
Pittsfield-17	Room 106, Combination Sink, Faucet	2:50 PM	Bioswab	0.00	36.1	8.37	ND	ND	ND	<20
Pittsfield-17	Room 106, Combination Sink, Faucet	2:55 PM	1 Liter	0.00	36.1	8.37	ND	ND	ND	<0.1
Pittsfield-36	Music room, Combination Sink, Faucet	2:00 PM	Bioswab	0.01	32.5	8.33	ND	ND	ND	<20
Pittsfield-36	Music room, Combination Sink, Faucet	2:05 PM	1 Liter	0.01	32.5	8.33	ND	ND	ND	<0.1

- 1) <0.1 is the detection limit for Legionella in bulk water samples
- 2) <20 is the detection limit for Legionella in bioswab samples
- 3) See attached analytical results for full list of other Legionella species



Ann Arbor Public Schools
Legionella Sampling Analysis
Project Number: AE200779

Pittsfield Elementary School										
Date of Sampling: 11-05-20										
Sampler: Brendan Koziol										
Sample #	Location	Time Collected	Bottle Type	Chlorine (ppm)	Temp °C	pH	Legionella Pneumophila Lab Result	Other Legionella Species ³ Lab Results	Total Legionella raw ct.	Total Legionella (cfu (colony forming units)/ml)
Pittsfield-HWH	Hot Water Heater in Boiler Room	9:30 AM	1 Liter	0.00	34.0	8.45	ND	ND	ND	<0.1

1) <0.1 is the detection limit for Legionella in bulk water samples

2) <20 is the detection limit for Legionella in bioswab samples

3) See attached analytical results for full list of other Legionella species

Pittsfield Elementary School Sampling Results Table

Pittsfield Elementary School				
Location	Parameter	Result	MCL/AL	Method Reference
Pittsfield-02: Staff Lounge, Kitchen Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
Pittsfield-22: Room 105, Combination Sink, Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
Pittsfield-30: Room 114, Combination Sink, Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
Pittsfield-37: Kitchen, Three-Compartment Sink, Single Add On Faucet, Far Right	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
	Total Residual Chlorine	0.0 PPM	N/A	N/A