



**Ann Arbor Public Schools
Legionella Sampling Analysis
Project Number: AE200779**

Slauson Middle School										
Date of Sampling: 11-05-20										
Sampler: Jackie Keeler										
Sample #	Location	Time Collected	Bottle Type	Chlorine (ppm)	Temp °C	pH	Legionella Pneumophila Lab Result	Other Legionella Species ³ Lab Results	Total Legionella raw ct.	Total Legionella (cfu (colony forming units)/ml)
Slauson-10	Room 138, 2 Compartment Sink, Kitchen Faucet	10:55 AM	Bioswab	0.01	28.1	9.26	ND	ND	ND	<20
Slauson-10	Room 138, Two-Compartment Sink, Kitchen Faucet	11:00 AM	1 Liter	0.01	28.1	9.26	ND	ND	ND	<0.1
Slauson-31	Computer Room, Rooms 300 and 300A, Faucet	10:40 AM	Bioswab	0.00	20.2	9.36	ND	ND	ND	<20
Slauson-31	Computer Room, Rooms 300 and 300A, Faucet	10:45 AM	1 Liter	0.00	20.2	9.36	ND	ND	ND	<0.1

- 1) <0.1 is the detection limit for Legionella in bulk water samples
- 2) <20 is the detection limit for Legionella in bioswab samples
- 3) See attached analytical results for full list of other Legionella species

STEAM at Northside Sampling Results Table

STEAM at Northside				
Location	Parameter	Result	MCL/AL	Method Reference
STEAM -20: Room 101, Combination Sink, Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
	Total Residual Chlorine	0.01 PPM	N/A	N/A
STEAM-26: Room MS1, in Closet, Single Sink, Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
STEAM-36: Room 401, Combination Sink, Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
STEAM-41: Media Center, Single Sink, Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Positive	Zero	ATP D05-0035
STEAM-43: Kitchen, Three-Compartment Sink, Add on Faucet, Far Right	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
STEAM-55: Room 201, Combination Sink, Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035

Slauson Middle School Sampling Results Table

Slauson Middle School				
Location	Parameter	Result	MCL/AL	Method Reference
Slauson-10: Room 138, Two-Compartment Sink, Kitchen Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
Slauson-31: Computer Room, Rooms 300 and 300A, Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
	Total Residual Chlorine	0.0 PPM	N/A	N/A
Slauson-35: Kitchen, Three-Compartment Sink, Single Add on Faucet, Far Right	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
Slauson-38: Room 203, Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
Slauson-39: Clinic, Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
Slauson-45: Hallway, Outside Room 348, Hydration Station, Bottle Fill	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035