



August 28, 2021

Mr. Jason Bing, RA, LEED AP
Construction Projects Auditor, Physical Properties
Ann Arbor Public Schools
2555 South State Street
Ann Arbor, Michigan 48104

RE: **Project #AE210718**
Asbestos Bulk Sample Results
Community High School

Dear Mr. Bing:

Attached are the results of the bulk samples, collected by Arch Environmental Group, Inc. (AEG), from the above referenced site for asbestos analysis. The samples were analyzed utilizing Polarized Light Microscopy (PLM), according to the EPA-600/M4-82-020 Interim Method.

The materials were collected from locations associated with occupant concerns. The following materials were sampled and analyzed as ASBESTOS-CONTAINING.

- NONE

All other suspect materials were sampled and analyzed as non-asbestos-containing. The sample result information is attached for your review. AEG will include copies of this bulk sample report in the school's management plan.

Arch Environmental Group, Inc. looks forward to working with you in the future and helping you to address any concerns regarding environmental health and safety. If you have any questions regarding this report, or if I can be of further assistance please feel free to contact me at (248) 426-0165.

Sincerely,

Arch Environmental Group, Inc.
Environmental Services

A handwritten signature in black ink, appearing to read 'R. Austin III', with a stylized flourish at the end.

Roosevelt Austin, III
Manager, healthAIR

Attachments: Bulk Sampling and Laboratory Information
Asbestos Bulk Sample Analysis Report
Official Laboratory Sample Results

File: AE210718

BULK SAMPLING and LABORATORY INFORMATION

The information listed below is provided to summarize pertinent information regarding the collection and analysis of the bulk sample(s).

BULK SAMPLING INFORMATION

Date of Sampling: August 27, 2021

Name of Accredited Inspector who collected Bulk Sample(s):

Name: Roosevelt Austin, III
Accreditation Number: A28791
State of Accredited: Michigan
Accred. Exp. Date: January 4, 2022
Training Exp. Date: May 13, 2022

Signature of Accredited Inspector who collected Bulk Sample(s):



LABORATORY INFORMATION

Name of Laboratory: APEX Research Laboratories

Address of Laboratory: 11054 Hi Tech Drive
Whitmore Lake, Michigan 48189

Name of Analyst: Robert T. Letarte

Signature of Analyst: See Attached Laboratory Results Sheet

NVLAP Number: 102118

Laboratory Statement of Accreditation:

All samples collected by Arch Environmental Group, Inc. are analyzed for asbestos by laboratories accredited under the National voluntary Laboratory Accreditation Program (NVLAP), in accordance with 40 CFR, Part 763.87(a). This program is provided under the auspices of the United States Department of Commerce National Institute of Standards and Technology. The NVLAP Accreditation Number for the laboratory which performed the asbestos bulk analysis on the samples collected is provided above and noted on the Official Laboratory Results.



ASBESTOS BULK SAMPLE ANALYSIS RESULTS

Client: Ann Arbor Public Schools
Building: Community High School
Location: Multiple Locations
Project #: AE210718

Samples Collected By: Roosevelt Austin, III
Sample Collection Date: August 27, 2021
Samples Analyzed By: APEX Research, Inc.
Sample Analysis Date: August 28, 2021

Sample #	HA Description	Sample Location	Results
AE210718-TL-01	Tape	Room 113 Teacher's Desk	No Asbestos Observed
AE210718-TL-02	Tape	Room 113, E. Wall Counter by Microwave	No Asbestos Observed
AE210718-TL-03	Tape	Main Office, Secretary Desk	No Asbestos Observed
AE210718-TL-04	Tape	Main Office, Copy Room Counter by Oven	No Asbestos Observed
AE210718-TL-05	Tape	Room 212 Teacher's Desk	No Asbestos Observed
AE210718-TL-06	Tape	Room 212 E. Wall S. Window Stool	No Asbestos Observed
AE210718-TL-07	Tape	Room 314 White Board Marker Tray	No Asbestos Observed
AE210718-TL-08	Tape	Room 314 Center Student Desk	No Asbestos Observed
AE210718-TL-09	Tape	Room 306 File Cabinet NE Corner	No Asbestos Observed
AE210718-TL-10	Tape	Room 306 Student Desk Top on S. Wall	No Asbestos Observed
AE210718-TL-11	Tape	Room 317 White Board Marker Tray	No Asbestos Observed
AE210718-TL-12	Tape	Room 317 Desk Counter w/Gas Controls	No Asbestos Observed

Official Laboratory Results are attached.

Asbestos-Containing Materials (ACM) means "Any material or product which contains more than 1% asbestos" (40 CFR 763.83)