



February 7, 2022

Mr. Bernie Rice  
Executive Director, Physical Properties  
Ann Arbor Public Schools  
2555 South State Street  
Ann Arbor, Michigan 48104

RE: **Project #AE210780**  
Asbestos Baseline Air Sampling Report  
Community High School

Dear Mr. Rice:

Per your request, Arch Environmental Group, Inc. (AEG) conducted asbestos baseline air sampling activities at Community High School on February 4, 2022. The collected air samples have been analyzed utilizing Phase Contrast Microscopy (PCM) in accordance with NIOSH 7400 Methodologies. AEG uses the following nomenclature for referencing different types of air samples:

FB	Field Blank
BL	Baseline Sample

**All PCM baseline air samples collected at Community High School on February 4, 2022, were analyzed below the AHERA PCM Clearance Level of 0.01 fibers per cubic centimeter (f/cc).**

Arch Environmental Group, Inc. looks forward to working with you in the future and helping you to address any concerns regarding environmental health and safety. If you have any questions regarding this report, or if I can be of further assistance please feel free to contact me at (248) 426-0165.

Sincerely,

**Arch Environmental Group, Inc.**  
**Environmental Services**

A handwritten signature in black ink, appearing to read 'Wendy Ramsey', is positioned above the typed name.

Wendy Ramsey  
Technical Administrative Assistant, healthAIR

Attachments: Asbestos Daily Project Reports

File: AE210780

**Attachment**  
Asbestos Daily Project Reports



**ASBESTOS DAILY PROJECT REPORTS**  
**Air Sample Analysis Information**

<b>Client:</b> Ann Arbor Public Schools	<b>Samples Collected By:</b> Tinh Nguyen
<b>Building:</b> Community High School	<b>Sample Collection Date:</b> 2/4/2022
<b>Location:</b> Throughout Building	<b>Samples Analyzed By:</b> Tinh Nguyen
<b>Project #:</b> AE210780	<b>Sample Analysis Date:</b> 2/4/2022

Sample ID	Sample Location	Start/End	Total Time (min)	Flow Rate (Lpm)	Volume (L)	Concentration (f/cc)	Density (f/mm <sup>2</sup> )
FB1	Sample prepared on-site.	--	--	--	--	--	0.00
FB2	Sample prepared on-site.	--	--	--	--	--	0.00
BL1	In hallway outside room 118	12:40 PM	140	14.620	2047	0.001	0.00
		3:00 PM					
BL2	In hallway outside room 117	12:40 PM	140	15.030	2104	0.001	0.00
		3:00 PM					
BL3	In hallway outside room 213	12:45 PM	140	14.400	2016	0.001	0.00
		3:05 PM					
BL4	In hallway outside room 224	12:45 PM	140	14.620	2047	0.001	0.00
		3:05 PM					
BL5	In room 300	12:50 PM	140	14.560	2038	0.001	0.00
		3:10 PM					

AHERA PCM Clearance Level = 0.010 f/cc  
 AHERA TEM Clearance Level = 70 AS/mm<sup>2</sup>  
 State of Michigan PCM Clearance Level = 0.050 f/cc

**Project Area Clearance Information**

Passed