



March 1, 2022

Mr. Bernie Rice
Executive Director, Physical Properties
Ann Arbor Public Schools
2555 South State Street
Ann Arbor, Michigan 48104

RE: **Project #AE210780**
Asbestos Baseline Air Sampling Report
Community High School

Dear Mr. Rice:

Per your request, Arch Environmental Group, Inc. (AEG) conducted asbestos baseline air sampling activities at Community High School on February 28, 2022. The collected air samples have been analyzed utilizing Phase Contrast Microscopy (PCM) in accordance with NIOSH 7400 Methodologies. AEG uses the following nomenclature for referencing different types of air samples:

FB	Field Blank
BL	Baseline Sample

All PCM baseline air samples collected at Community High School on February 28, 2022, were analyzed below the AHERA PCM Clearance Level of 0.01 fibers per cubic centimeter (f/cc).

Arch Environmental Group, Inc. looks forward to working with you in the future and helping you to address any concerns regarding environmental health and safety. If you have any questions regarding this report, or if I can be of further assistance please feel free to contact me at (248) 426-0165.

Sincerely,

Arch Environmental Group, Inc.
Environmental Services

A handwritten signature in black ink, appearing to read 'Wendy Ramsey', is written over a faint, light-colored signature line.

Wendy Ramsey
Technical Administrative Assistant, healthAIR

Attachments: Asbestos Daily Project Reports

File: AE210780

Attachment
Asbestos Daily Project Reports



ASBESTOS DAILY PROJECT REPORTS
Air Sample Analysis Information

Client:	Ann Arbor Public Schools	Samples Collected By:	Thinh Nguyen
Building:	Community High School	Sample Collection Date:	2.28.2022
Location:	Media Center/Library	Samples Analyzed By:	Thinh Nguyen
Project #:	AE210780	Sample Analysis Date:	2.28.2022

Sample ID	Sample Location	Start/End	Total Time (min)	Flow Rate (Lpm)	Volume (L)	Concentration (f/cc)	Density (f/mm ²)
FB1	Sample prepared on-site.	--	--	--	--	--	2.55
FB2	Sample prepared on-site.	--	--	--	--	--	2.55
BL1	In Media Center, underneath penetration	11:15 AM	120	14.400	1728	0.002	10.19
		1:15 PM					

AHERA PCM Clearance Level = 0.010 f/cc
 AHERA TEM Clearance Level = 70 AS/mm²
 State of Michigan PCM Clearance Level = 0.050 f/cc

Project Area Clearance Information

Passed