



September 23, 2022

Mr. Jason Bing, RA, LEED AP  
Director of Capital Programs, Physical Properties  
Ann Arbor Community Schools  
2555 South State Street  
Ann Arbor, Michigan 48104

RE: **Project #AE220739**  
Asbestos Baseline Air Sampling Report  
Community High School

Dear Mr. Bing:

Per your request, Arch Environmental Group, Inc. (AEG) conducted asbestos baseline air sampling activities at Community High School on September 9, 2022. The collected air samples have been analyzed utilizing Phase Contrast Microscopy (PCM) in accordance with NIOSH 7400 Methodologies. AEG uses the following nomenclature for referencing different types of air samples:

FB	Field Blank
BL	Baseline Sample

**All PCM baseline air samples collected at Community High School on September 9, 2022, were analyzed below the AHERA PCM Clearance Level of 0.01 fibers per cubic centimeter (f/cc).**

Arch Environmental Group, Inc. looks forward to working with you in the future and helping you to address any concerns regarding environmental health and safety. If you have any questions regarding this report, or if I can be of further assistance please feel free to contact me at (248) 426-0165.

Sincerely,

**Arch Environmental Group, Inc.**  
Environmental Services

A handwritten signature in black ink, appearing to read 'Sheri Carriere', is written over a light blue horizontal line.

Sheri Carriere  
Project Consultant I, healthAIR

Attachments: Asbestos Daily Project Reports

File: AE220739

**Attachment**  
Asbestos Daily Project Reports



**ASBESTOS DAILY PROJECT REPORTS**  
**Air Sample Analysis Information**

<b>Client:</b> Ann Arbor Public Schools	<b>Samples Collected By:</b> Sheri Carriere
<b>Building:</b> Community High School	<b>Sample Collection Date:</b> 9/9/2022
<b>Location:</b> Throughout	<b>Samples Analyzed By:</b> Sheri Carriere
<b>Project #:</b> AE220739	<b>Sample Analysis Date:</b> 9/9/2022

Sample ID	Sample Location	Start/End	Total Time (min)	Flow Rate (Lpm)	Volume (L)	Concentration (f/cc)	Density (f/mm <sup>2</sup> )
FB1	Sample prepared on-site.	--	--	--	--	--	0.64
FB2	Sample prepared on-site.	--	--	--	--	--	0.64
BL1	Hall outside of Room 315	4:30PM	130	14.750	1918	0.001	7.01
		6:40PM					
BL2	Room 207 Library	4:35PM	130	14.490	1884	0.003	16.56
		6:45PM					
BL3	Room 222	4:40PM	130	14.740	1916	0.002	8.92
		6:50PM					
BL4	Room 109	4:45PM	130	15.050	1957	0.001	6.37
		6:55PM					
BL5	Hall outside of Room 113	4:50PM	130	15.520	2018	0.001	8.28
		7:00PM					

AHERA PCM Clearance Level = 0.010 f/cc  
 AHERA TEM Clearance Level = 70 AS/mm<sup>2</sup>  
 State of Michigan PCM Clearance Level = 0.050 f/cc

**Project Area Clearance Information**

Passed