



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Allen Elementary School							
Date of Sampling: 11/3/2018							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Allen-31	Room C-10, Bubblers	C	11:07 AM	5	11	N	First Draw

Allen Elementary School							
Date of Sampling: 12/22/2018							
Sampler: Gary Bosh							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Allen-31	Room C-10, Bubblers	C	6:36 AM	5	1	N	Follow-Up First Draw Following Replacem

1) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested