



Ann Arbor Public Schools
 Lead Drinking Water Analysis
 Project Number: AE180861

Dicken Elementary School							
Date of Sampling: 10/13/18							
Sampler: Lauren Koloski							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Dicken-09	Room 113, Left Combination Sink, Bubblers	C	10:03 AM	5	1	N	First Draw
Dicken-10	Room 113, Right Combination Sink, Faucet	C	10:03 AM	5	2	Y	First Draw
Dicken-11	Room 109, Faucet	C	9:56 AM	5	2	Y	First Draw
Dicken-12	Room 107, Faucet	C	9:53 AM	5	1	Y	First Draw
Dicken-13	Room 122, Bubblers	C	9:24 AM	5	4	N	First Draw
Dicken-14	Room 120, Bubblers	C	9:27 AM	5	1	N	First Draw
Dicken-15	Room 118, Bubblers	C	9:29 AM	5	3	N	First Draw
Dicken-16	Room 116, Bubblers	C	9:30 AM	5	2	N	First Draw
Dicken-17	Room 119, Bubblers	C	9:23 AM	5	2	N	First Draw
Dicken-18	Room 117, Bubblers	C	9:26 AM	5	2	N	First Draw
Dicken-19	Room 102, Bubblers	C	9:45 AM	5	ND ³	N	First Draw
Dicken-20	Room 104, Bubblers	C	9:48 AM	5	1	N	First Draw
Dicken-21	Room 106, Bubblers	C	9:50 AM	5	ND	N	First Draw
Dicken-22	Room 108, Bubblers	C	9:54 AM	5	1	N	First Draw
Dicken-23	Room 110, Bubblers	C	9:58 AM	5	ND	N	First Draw
Dicken-24	Room 112, Bubblers	C	9:59 AM	5	ND	N	First Draw
Dicken-25	Room 114, Right Combination Sink, Bubblers	C	10:02 AM	5	1	N	First Draw

1) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



Ann Arbor Public Schools
 Lead Drinking Water Analysis
 Project Number: AE180861

Dicken Elementary School							
Date of Sampling: 10/13/18							
Sampler: Lauren Koloski							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Dicken-27	Room 111, Bubblers	C	10:00 AM	5	1	N	First Draw
Dicken-28	Room 109, Bubblers	C	9:56 AM	5	ND	N	First Draw
Dicken-29	Room 107, Bubblers	C	9:53 AM	5	ND	N	First Draw
Dicken-30	Room 105, Bubblers	C	9:49 AM	5	ND	N	First Draw
Dicken-31	Room 103, Bubblers	C	9:46 AM	5	1	N	First Draw
Dicken-32	Hallway Outside Room 123, Bottle Fill	BT	9:33 AM	5	1	N	First Draw
Dicken-33	Hallway Outside Room 123, Bottle Fill, Water Cooler	BT	9:33 AM	5	ND	N	First Draw
Dicken-34	Room 128, Bubblers	C	Not Sampled			Low Flow, No Sample Collected.	
Dicken-35	Room 126, Bubblers	C	Not Sampled			Out of Service, No Sample Collected.	
Dicken-36	Gym, Bubblers	B	8:52 AM	5	1	N	First Draw
Dicken-37	Kitchen, 2-Compartment, Faucet	KF	9:35 AM	5	3	Y	First Draw
Dicken-38	Kitchen, 3-Compartment, Faucet	KF	9:35 AM	5	1	Y	First Draw

1) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



Ann Arbor Public Schools
 Lead Drinking Water Analysis
 Project Number: AE180861

Dicken Elementary School							
Date of Sampling: 10/20/18							
Sampler: Jenna Sendra							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Dicken-02	Main Office, Nurses Sink	KF	10:17 AM	5	ND	Y	First Draw
Dicken-40	Room 111, Faucet	C	10:06 AM	5	1	Y	First Draw
Dicken-41	Room 110, Faucet	C	10:04 AM	5	ND	Y	First Draw
Dicken-42	Room 108, Faucet	C	10:01 AM	5	ND	Y	First Draw
Dicken-43	Room 106, Faucet	C	9:59 AM	5	2	Y	First Draw
Dicken-44	Room 105, Faucet	C	10:08 AM	5	ND	Y	First Draw
Dicken-45	Room 103, Faucet	C	10:13 AM	5	2	Y	First Draw
Dicken-46	Room 102, Faucet	C	9:57 AM	5	ND	Y	First Draw
Dicken-47	Room 117, Faucet	C	9:55 AM	5	1	Y	First Draw
Dicken-48	Room 119, Faucet	C	9:52 AM	5	2	Y	First Draw
Dicken-49	Room 122, Faucet	C	9:31 AM	5	2	Y	First Draw
Dicken-50	Room 120, Faucet	C	9:48 AM	5	1	Y	First Draw
Dicken-52	Room 116, Faucet	C	9:45 AM	5	3	Y	First Draw
Dicken-53	Room 128, Faucet	C	9:40 AM	5	1	Y	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



Ann Arbor Public Schools
 Lead Drinking Water Analysis
 Project Number: AE180861

Dicken Elementary School							
Date of Sampling: 10/27/18							
Sampler: Jenna Sendra							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Dicken-01	Hallway, Adjacent from Room 123	F	12:29 PM	5	ND	Y	First Draw
Dicken-03	Room 104, Bubbler	C	12:31 PM	5	ND	N	First Draw
Dicken-04	Room 112, Faucet	C	12:31 PM	5	ND	Y	First Draw
Dicken-05	Room 114, Left Combination Sink, Faucet	C	12:36 PM	5	2	Y	First Draw
Dicken-06	Room 114, Left Combination Sink, Bubbler	C	12:37 PM	5	ND	N	First Draw
Dicken-07	Room 114, Right Combination Sink, Bubbler	C	12:38 PM	5	2	N	First Draw
Dicken-08	Room 113, Left Combination Sink, Faucet	C	12:34 PM	5	3	Y	First Draw

Dicken Elementary School							
Date of Sampling: 11/10/18							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Dicken-39	Main Office, Kitchen Sink	KF	1:47 PM	5	ND	Y	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861

Dicken Elementary School							
Date of Sampling: 01/12/19							
Sampler: Jenna Sendra							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Dicken-34	Room 128, Bubbler	C	10:51 AM	5	2	N	First Draw
Dicken-35	Room 126, Bubbler	C	10:56 AM	5	38	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminante>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested

Action Level >5ppb