



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Pattengill Elementary School							
Date of Sampling: 10/27/2018							
Sampler: Lindsey Eveleth							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pattengill -01	Teachers Lounge, Kitchen Sink	KF	11:46 AM	5	10	Y	First Draw. Water Leaks from Base of Faucet.
Pattengill -36	Room B-11, Faucet	C	12:24 PM	5	6	Y	First Draw

Pattengill Elementary School							
Date of Sampling: 12/08/2018							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pattengill-01A	Teachers Lounge, Kitchen Sink	KF	4:45 PM	5	8	Y	Follow-Up First Draw Following Replacement
Pattengill-36A	Room B-11, Faucet	C	4:50 PM	5	2	Y	Follow-Up First Draw Following Replacement

Pattengill Elementary School							
Date of Sampling: 12/22/2018							
Sampler: Gary Bosh							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pattengill-01B	Teachers Lounge, Kitchen Sink	KF	6:25 AM	5	3	Y	2nd Follow-Up First Draw Following Replacement

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested