



Ann Arbor Public Schools  
 Lead Drinking Water Analysis  
 Project Number: AE180861

Skyline High School							
Date of Sampling: March 29, 2019							
Sampler: Amanda Peterson							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Skyline-01	Room C104, Choir Room, Right Bubbler	B	10:40 AM	5	ND <sup>3</sup>	N	First Draw. Water cooler was reviewed against the EPA Fact Sheet to determine that it is not a lead lined.
Skyline-02	Room C104, Choir Room, Left Bubbler	B	10:42 AM	5	ND	N	First Draw
Skyline-03	Room C110, Right Bubbler	B	10:46 AM	5	ND	N	First Draw
Skyline-04	Room C110, Left Bubbler	B	10:48 AM	5	ND	N	First Draw
Skyline-05	Main Office Suite, Room A204-D, Kitchen Sink	KF	12:46 PM	5	6	Y	First Draw
Skyline-06	Room B424, Clinic Single Sink	F	11:36 AM	5	ND	Y	First Draw. Corrosion observed on aerator.
Skyline-07	Room C116, Left Bubbler	B	10:50 AM	5	ND	N	First Draw
Skyline-08	Room C116, Right Bubbler	B	10:52 AM	5	ND	N	First Draw
Skyline-09	Pool Deck, Single Water Cooler	WC	10:20 AM	5	ND	N	First Draw
Skyline-10	Pool Deck, Single Bottle Fill	BF	10:22 AM	5	ND	Y	First Draw
Skyline-11	Room B111, Dressing Room 1, Faucet	F	10:36 AM	5	22	Y	First Draw
Skyline-12	Room B331, Kitchen Sink	KF	12:30 PM	5	ND	Y	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminante>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested

Action Level >5ppb



Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE180861

Skyline High School							
Date of Sampling: March 29, 2019							
Sampler: Amanda Peterson							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Skyline-13	Boy's Pool Locker Room, Right Bubbler	B	10:24 AM	5	ND	N	First Draw. Corrosion observed on aerator.
Skyline-14	Boy's Pool Locker Room, Left Bubbler	B	10:26 AM	5	2	N	First Draw. Corrosion observed on aerator.
Skyline-15	Girl's Locker Room for Pool, Left Bubbler	B	10:28 AM	5	ND	N	First Draw
Skyline-16	Girl's Pool Locker Room, Right Bubbler	B	10:30 AM	5	ND	N	First Draw
Skyline-17	Room B111, Small Attachment Room, Faucet	Not Sampled. Water Shut Off					
Skyline-18	Room B111, Dressing Room 2, Faucet	F	10:34 AM	5	5	Y	First Draw
Skyline-19	Dressing Room 3, Adjacent to Greenroom, Faucet	Not Sampled. Water Shut Off					
Skyline-20	Greenroom, Kitchen Faucet	F	11:00 AM	5	1	Y	First Draw
Skyline-22	Room A119, Ice Machine	I	10:06 AM	5	1	N	First Draw
Skyline-23	Room A119, Faucet near Ice Machine	F	10:04 AM	5	ND	Y	First Draw
Skyline-24	Room A119, Athletic Training Room, Faucet in Main Room	F	10:00 AM	5	2	Y	First Draw
Skyline-25	Main Gym, Left Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminante>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE180861

Skyline High School							
Date of Sampling: March 29, 2019							
Sampler: Amanda Peterson							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Skyline-26	Main Gym, Right Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Skyline-27	Auxiliary Gym, North Wall, Left Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Skyline-28	Auxiliary Gym, North Wall, Right Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Skyline-29	Auxiliary Gym, South Wall by Weight Room, Right Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Skyline-30	Auxiliary Gym, South Wall by Weight Room, Left Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Skyline-31	Weight Room, Faucet	F	11:06 AM	5	ND	Y	First Draw
Skyline-32	Room A220, Photography Classroom, Faucet	F	12:40 PM	5	1	Y	First Draw
Skyline-33	Floor 2, Room A225b, 3-Compartment Sink, Left Faucet	F	9:20 AM	5	ND	Y	First Draw
Skyline-34	Floor 2, Room A225b, 3-Compartment Sink, Right Faucet	F	9:22 AM	5	ND	Y	First Draw
Skyline-35	Floor 2, Room A225, Plumbed Coffee Machine	PC	9:24 AM	5	2	Y	First Draw
Skyline-36	Room C216, Staff Lounge, Kitchen Faucet	KF	11:22 AM	5	27	Y	First Draw
Skyline-42	Kitchen, North Wall, 3-Compartment Sink, Left Faucet	F	9:46 AM	5	1	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminante>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested

Action Level >5ppb



Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE180861

Skyline High School							
Date of Sampling: March 29, 2019							
Sampler: Amanda Peterson							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Skyline-43	Kitchen, North Wall, 3-Compartment Sink, Right Faucet	F	9:48 AM	5	1	N	First Draw
Skyline-44	Hallway, Floor 2, Outside C-214 & C-217 Woman's Restroom, Single Bottle Fill	BF	9:32 AM	5	ND	Y	First Draw
Skyline-45	Kitchen, Central Island, Single Compartment Sink	KF	9:50 AM	5	ND	Y	First Draw
Skyline-46	Hallway, Floor 2, Outside C-214 & C-217 Woman's Restroom, Single Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Skyline-47	Kitchen, Ice Machine	I	9:52 AM	5	ND	N	First Draw
Skyline-48	Room A303-A, Kitchen Faucet	KF	12:36 PM	5	ND	Y	First Draw
Skyline-49	Room B325, Kitchen Faucet	KF	12:10 PM	5	ND	Y	First Draw
Skyline-50	Room B324, Media Center Break Room, Kitchen Faucet	KF	12:12 PM	5	ND	Y	First Draw
Skyline-51	Hallway, Floor 3, Near Media Center, Outside Room B-325, Single Bottle Fill	BF	12:18 PM	5	ND	N	First Draw
Skyline-52	Hallway, Floor 3, Near Media Center, Outside Room B-325, Single Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Skyline-53	Hallway, Floor 3, Near Media Center, Outside Room B-331, Single Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Skyline-54	Hallway, Floor 3, Near Media Center, Outside Room B-331, Single Bottle Fill	BF	12:20 PM	5	ND	Y	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminante>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE180861

Skyline High School							
Date of Sampling: March 29, 2019							
Sampler: Amanda Peterson							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Skyline-55	Room B308, Faucet	F	12:26 PM	5	27	Y	First Draw
Skyline-56	Room C303-A, Kitchen Sink	KF	12:32 PM	5	1	Y	First Draw
Skyline-57	Room A403-A, Kitchen Sink	KF	12:06 PM	5	1	Y	First Draw
Skyline-58	Room B425, Equality Center, Kitchen Sink	KF	11:30 AM	5	ND	Y	First Draw
Skyline-59	Room B431, Administration, Kitchen Sink	KF	11:52 AM	5	2	Y	First Draw
Skyline-60	Hallway, Floor 4, Outside Room B-425, Single Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Skyline-61	Hallway, Floor 4, Outside Room B-425, Single Bottle Fill	BF	11:40 AM	5	1	N	First Draw
Skyline-62	Hallway, Floor 4, Outside Room B-431, Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Skyline-63	Hallway, Floor 4, Outside Room B-431, Single Bottle Fill	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Skyline-64	Room C403-A, Kitchen Faucet	KF	12:00 PM	5	1	Y	First Draw
Skyline-65	Hallway, Floor 2, Outside C-214 & C-215 Men's Restroom, Right Single Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Skyline-66	Hallway, Floor 2, Outside C-214 & C-215 Men's Restroom, Left Single Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested

Action Level >5ppb



Ann Arbor Public Schools  
 Lead Drinking Water Analysis  
 Project Number: AE180861

Skyline High School							
Date of Sampling: March 29, 2019							
Sampler: Amanda Peterson							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Skyline-67	Hallway, Floor 2, Outside C-227 Track & Woman's Restroom, Single Bottle Fill	BF	9:30 AM	5	ND	N	First Draw
Skyline-68	Hallway, Floor 2, Outside C-227 Track & Woman's Restroom, Single Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Skyline-69	Hallway, Floor 2, Outside C-227 Track & Men's Restroom, Left Single Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Skyline-70	Hallway, Floor 2, Outside C-227 Track & Men's Restroom, Right Single Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested