



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Westerman Preschool and Family Center							
Date of Sampling: 10/13/18							
Sampler: Lauren Koloski							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
PFC-01	Room C112, Left Faucet	F	Not sampled				Low Flow.
PFC-07	A108, Bubblers	F	Not sampled				Room used for Storage.
PFC-08	A108, Left Faucet	F	Not sampled				Room used for Storage.
PFC-13	Kitchen, 3-Comp Sink, Right Faucet	KF	6:02 AM	5	ND ³	N	First Draw
PFC-14	Kitchen, 3-Comp Sink, Left Faucet	KF	6:02 AM	5	3	N	First Draw
PFC-15	Kitchen Sprayer	KF	6:02 AM	5	ND	Y	First Draw
PFC-16	C105, Left Faucet	C	6:15 AM	5	3	Y	First Draw
PFC-17	C105, Bubblers	C	6:15 AM	5	ND	N	First Draw
PFC-18	C105, Right Faucet	F	6:15 AM	5	ND	Y	First Draw
PFC-19	C103, Right Faucet	F	6:21 AM	5	ND	N	First Draw
PFC-20	C103, Left Faucet	C	6:21 AM	5	1	Y	First Draw
PFC-21	C103, Bubblers	C	6:21 AM	5	ND	N	First Draw
PFC-22	C102, Right Faucet	C	6:25 AM	5	ND	Y	First Draw
PFC-23	C102, Bubblers	C	6:25 AM	5	ND	N	First Draw
PFC-24	C100, Left Faucet	C	6:28 AM	5	2	Y	First Draw
PFC-25	C100, Bubblers	C	6:28 AM	5	1	N	First Draw
PFC-26	C100, Right Faucet	F	6:28 AM	5	1	N	First Draw
PFC-27	C112, Bubblers	C	6:35 AM	5	ND	Y	First Draw
PFC-28	C112, Left Faucet	C	6:35 AM	5	2	Y	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Westerman Preschool and Family Center							
Date of Sampling: 10/13/18							
Sampler: Lauren Koloski							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
PFC-29	In Hallway Outside Room D109, Water Cooler	WC	6:32 AM	5	1	N	First Draw. Water cooler was reviewed against the EPA Fact Sheet to determine that it is not a lead lined.
PFC-30	D104, Right Faucet	C	6:36 AM	5	4	Y	First Draw
PFC-31	D104, Bubbler	C	6:36 AM	5	ND	N	First Draw
PFC-32	D104, Left Faucet	F	6:36 AM	5	1	Y	First Draw
PFC-33	D103, Right Faucet	F	6:45 AM	5	ND	Y	First Draw
PFC-34	D103, Bubbler	C	6:45 AM	5	ND	N	First Draw
PFC-35	D103, Left Faucet	C	6:45 AM	5	2	Y	First Draw
PFC-36	D102, Left Faucet	C	6:47 AM	5	1	Y	First Draw
PFC-37	D102, Right Faucet	F	6:47 AM	5	1	Y	First Draw
PFC-38	D100, Left Faucet	F	6:50 AM	5	1	Y	First Draw
PFC-39	E105, Kitchen Faucet	KF	6:56 AM	5	ND	Y	First Draw. Small Leak Observed.
PFC-40	E100, Left Faucet	F	6:58 AM	5	5	Y	First Draw. Automatic Sink
PFC-41	E100, Right Faucet	F	6:55 AM	5	3	Y	First Draw. Automatic Sink.
PFC-42	E100, Left Faucet	C	7:05 AM	5	3	Y	First Draw
PFC-43	B100, Bubbler	C	7:05 AM	5	ND	N	First Draw
PFC-44	B100, Right Faucet	F	7:05 AM	5	ND	Y	First Draw
PFC-45	B102, Left Faucet	F	7:08 AM	5	2	Y	First Draw
PFC-46	B102, Right Faucet	C	7:08 AM	5	1	Y	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Westerman Preschool and Family Center								
Date of Sampling: 10/13/18								
Sampler: Lauren Koloski								
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes	
PFC-47	B103, Left Faucet	F	7:13 AM	5	ND	Y	First Draw	
PFC-48	B103, Bubblers	C	7:13 AM	5	1	N	First Draw	
PFC-49	B103, Left Faucet	C	7:13 AM	5	2	Y	First Draw	
PFC-50	B105, Right Faucet	C	7:16 AM	5	2	Y	First Draw	
PFC-51	B105, Left Faucet	F	7:16 AM	5	ND	Y	First Draw	
PFC-52	A105, Right Faucet	C	7:25 AM	5	2	Y	First Draw	
PFC-53	A105, Bubblers	C	7:25 AM	5	1	N	First Draw	
PFC-54	A105, Left Bubblers	F	7:25 AM	5	1	Y	First Draw	
PFC-55	A103, Left Faucet	F	7:30 AM	5	1	Y	First Draw	
PFC-56	A103, Right Faucet	C	7:30 AM	5	2	Y	First Draw	
PFC-57	A103, Bubblers	C	7:30 AM	5	1	N	First Draw	
PFC-58	A102, Right Faucet	F	7:33 AM	5	3	Y	First Draw	
PFC-59	A102, Left Faucet	C	7:33 AM	5	4	Y	First Draw	
PFC-60	A100, Left Faucet	F	7:35 AM	5	2	Y	First Draw	
PFC-61	A100, Right Faucet	C	7:35 AM	5	1	Y	First Draw	
PFC-62	A107, Right Faucet	F	7:40 AM	5	4	Y	First Draw	
PFC-63	A107, Left Faucet	F	7:40 AM	5	3	Y	First Draw	
PFC-67	A108, Right Faucet	F	Not sampled					Room used for Storage.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Westerman Preschool and Family Center							
Date of Sampling: 10/27/18							
Sampler: Lindsey Eveleth							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
PFC-02	Room A102, Bubblers	C	9:58 AM	5	1	N	First Draw
PFC-03	Room A100, Bubblers	C	9:55 AM	5	ND	N	First Draw
PFC-04	Room B102, Bubblers	C	9:50 AM	5	ND	N	First Draw
PFC-05	Room B105, Bubblers	C	9:52 AM	5	ND	N	First Draw
PFC-06	Family Room E100, 2-Compartment Faucet	KS	9:33 AM	5	1	Y	First Draw
PFC-08	Room C-102, Left Faucet	F	9:20 AM	5	ND	Y	First Draw
PFC-10	Room D-100, Bubblers	C	9:24 AM	5	ND	N	First Draw
PFC-11	Room D-100, Faucet	C	9:26 AM	5	2	Y	First Draw
PFC-12	Room D12, Bubblers	C	9:36 AM	5	ND	N	First Draw
PFC-64	Hallway Outside B112, Water Cooler	WC	9:43 AM	5	ND	N	First Draw. Water cooler was reviewed against the EPA Fact Sheet to determine that it is not a lead lined.
PFC-65	Hallway Outside B112, Bottle Fill	BT	9:44 AM	5	ND	N	First Draw
PFC-66	Hallway Outside B112, Bottle Fill, Water Cooler	BT	9:45 AM	5	ND	N	First Draw. Water cooler was reviewed against the EPA Fact Sheet to determine that it is not a lead lined.

1) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb